

HMB RPD	SPECIFICATIONS OF LIGHT FITTINGS	DAP – 258/10M SHEET 1 OF 2
--------------------	---	---------------------------------------

W.O. No.	Capacity of Crane
9075.001.150	25/5T X 16M

1. SPECIFICATION OF LIGHTING TRANSFORMER & LIGHT FITTINGS:-

1.1 LIGHTING TRANSFORMER:-

Sheet steel enclosed, dust & vermin proof, dry type, natural air cooled, double wound copper, lighting transformer, 7.5 KVA, 415 / 240 V / 24 V, 50 Hz, single phase, 7 KVA for 240 V & 500 VA for 24 V minimum class-B insulated. The center tap shall be brought out to the terminal board for earthing. Primary shall have □5% & □10% tapping. The terminal board shall be suitable for two nos. of cable gland for 3X2.5 sq. mm cable. The successful tenderer shall submit GA Drg. indicating dimensions and technical data for approval.

2.0 SCOPE OF SUPPLY:-

Sl. No.	Item code	Description	Qty.
2.1	5533100377	Lighting transformer, 7.5KVA, 415/240V/24V, 50 Hz, single phase, 7KVA for 240V & 500VA for 24V.	1